







Fire Alarm Symbol Legend							
SYMBOL	DESCRIPTION	PART NUMBER	MODEL	QUANTITY	USER TEXT	UL	FM
 30CD	HORN/STROBE, 2 WIRE, M-C, RED, CEILING	GCC24-CR	GCC24CR	2		464, 1971	Approved
 75CD	HORN/STROBE, 2 WIRE, M-C, RED, CEILING	GCC24-CR	GCC24CR	2		464, 1971	Approved
 30CD	STROBE, M-C, RED, CEILING	GCS24CR	GCS24CR	1		464, 1971	Approved
 30CD	STROBE, M-C, RED, WALL	GES3-24WR	GES3-24WR	2	EX	464, 1971	Approved
 30CD	HORN/STROBE, 2 WIRE, M-C, RED, WALL	GEC3-24WR	GEC3-24WR	1	EX	464, 1971	Approved

Must Remain On Site

GENERAL NOTES / SCOPE OF WORK

1. FACTORY RECOMMENDED MINIMUM WIRING SIZES, TYPE AND CONSTRUCTION AS NOTED ON THE DRAWINGS MUST BE STRICTLY FOLLOWED. ANYONE WISHING TO MAKE CHANGES WILL DO SO AT THERE OWN RISK!!
2. THE CIRCUIT ROUTING AND WIRING COUNTS ON THE FLOOR PLAN DRAWINGS ARE SHOWN DIAGRAMMATIC BASED ON CONTINUOUS AND SHORTEST POSSIBLE ROUTING FROM THE CONTROL PANEL AND BETWEEN CONNECTED FIELD DEVICES WITH NO PHYSICAL OBSTRUCTIONS. THE WIRING OR CIRCUIT COUNTS (IF SHOWN) ARE PROVIDED AS A CONVENIENCE ONLY AND AS MEANS TO HASTEN INSTALLATION OR TO DETERMINE WIRING ROUTS.
3. WIRE SHOWN IN THIS DRAWING SET IS PERMITTED IN RACEWAYS LEADING TO FIRE PROTECTION EQUIPMENT. OTHER WIRE SHALL NOT BE PERMITTED.
4. FIRE ALARM SYSTEM INSTALLATION SHALL CONFORM WITH THE LATEST U.L., N.E.C., N.F.P.A., W.A.C., AND OTHER STANDARDS AS APPLICABLE TO THE CITY STANDARDS.
5. WHEN NECESSARY, DUE TO CHANGING DESIGN REQUIREMENTS, FACTORY AVAILABILITY, ETC. FIRE SYSTEMS WEST RESERVES THE RIGHT TO SUBSTITUTE EQUIPMENT HEREIN MENTIONED OR SPECIFIED, WITH EQUIPMENT OF EQUAL OR BETTER QUALITY, FUNCTION AND DESIGN.
6. PARALLEL BRANCHING OF WIRE TO ALL NOTIFICATION APPLIANCE CIRCUITS SHALL NOT BE PERMITTED.
7. PARALLEL BRANCHING OF WIRE TO ANALOG INITIATING DEVICE CIRCUITS IS PERMISSIBLE.
8. FIRE SYSTEMS WEST IS INSTALLING A FIRE ALARM SYSTEM TO THE LAKESIDE APARTMENTS.

FIRE ALARM SYSTEM INFORMATION	
INSTALLER/SUPPLIER	
SITE CONTACT:	DESIGNER/SUPPLIER:
PARK PLACE LOBBY	FIRE SYSTEMS WEST, INC.
401 PARK PLACE	206 FRONTAGE ROAD NORTH, STE C
KIRKLAND, WA 98033	PACIFIC, WASHINGTON 98047
PHONE:	PHONE: (253) 833-1248
FAX:	FAX: (253) 735-0113
WA ST LICENSE: FIRESWI140B1	WA ST LICENSE: FIRESWI055LW
DESIGNER	
MATT CARLMAN	
FIRE SYSTEMS WEST, INC	
206 FRONTAGE ROAD NORTH, STE C	
PACIFIC, WASHINGTON 98047	
PHONE: (253) 833-1248	
FAX: (253) 735-0113	
<div>X </div>	
<div>FOR FIRE DEPARTMENT USE ONLY</div>	

A	142 FPLP
B	162 FPLP
EX	EXISTING LOCATION
WP	WEATHER PROOF
N	NEW DEVICE
R	RELOCATE

*STROBE COVERAGE AREA SHALL BE DEFINED AS:			
10 ft. C.O. HT.	20 ft. C.O. HT.	30 ft. C.O. HT.	
15' od = 20'x20'	25' od = 20'x20'	75' od = 30'x20'	
25' od = 30'x20'	75' od = 30'x20'	85' od = 30'x20'	
85' od = 50'x20'	110' od = 50'x20'	115' od = 50'x20'	